

2023 WEEKLY DRENCH HOSE CHECK

Location: _____

“Checked” indicates that eyewash station was activated for five minutes and water was clear.

Shower was activated for few minutes and water was clear.

Problems with your Eyewash? Contact Facilities Management:

Main Campus: 1-1385 **TUH/Health Science Center:** 2-4702

Episcopal: 2-1078 **Jeanes:** 215-728-2129 **NACC:** www.stonehenge.bz

Week of	Water Pressure Checked	Water Color Checked	Comments
1/1/2023			
1/8/2023			
1/15/2023			
1/22/2023			
1/29/2023			
2/5/2023			
2/12/2023			
2/19/2023			
2/26/2023			
3/5/2023			
3/12/2023			
3/19/2023			
3/26/2023			
4/2/2023			
4/9/2023			
4/16/2023			
4/23/2023			
4/30/2023			
5/7/2023			
5/14/2023			
5/21/2023			
5/28/2023			
6/4/2023			
6/11/2023			
6/18/2023			
6/25/2023			
7/2/2023			
7/9/2023			
7/16/2023			
7/23/2023			
7/30/2023			
8/6/2023			
8/13/2023			
8/20/2023			
8/27/2023			
9/3/2023			
9/10/2023			
9/17/2023			
9/24/2023			
10/1/2023			
10/8/2023			
10/15/2023			
10/22/2023			
10/29/2023			
11/5/2023			
11/12/2023			
11/19/2023			
11/26/2023			
12/3/2023			
12/10/2023			
12/17/2023			
12/24/2023			
12/31/2023			